

Tent and Canopies Checklist

Tent/Canopy location and layout are according to approved plans shall not be located within 20 feet of buildings, lot lines and vehicles.

Fire extinguisher for general use located at exit and readily accessible, classification 2A:10B:C.

Cooking and heating equipment shall not be located within 10 feet of tents/canopies, if deep frying: one K-rated fire extinguisher will be provided.

Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20 feet of a tent/canopy.

Portable LP gas containers shall be securely fastened in place to prevent unauthorized movement.

Generators shall not be located within 20 feet of tents/canopies.

Compressed gas cylinders including propane, oxygen, helium, or other are stored in an upright position and secured to prevent accidental tipping.

Flammable liquid fueled equipment shall not be used in tent or membrane structures.

Occupant load sign shall be posted in a conspicuous location.

Seating shall comply with California Fire Code Chapter 10.

Travel distance shall not exceed 100 feet to an exit.

Exits shall be clearly marked. With an occupant load of 50 or more exit signs will be internally or externally illuminated.

All tents, canopies or temporary membrane structures shall have a permanently affixed label from the Office of the State Fire Marshal stating that the material used for the structure is California State Fire Marshal licensed applicator per CFC 3104.

Other requirements may apply. Tents and temporary membrane structures shall comply with all applicable laws and regulation.